



**OFFICE OF SENIOR MEDICAL OFFICER
SDCH GANNAUR SONIPAT**

Ph no - 0130-2461102 Email- smo.chcgannaur@gmail.com



**PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE**

No.:SDCH/G-24/.1007

Date:- 10/09/2024

It is certified that an inspection team headed by Dr. Mohit, Medical Officer Incharge and Shri Joginder, Health Inspector PHC Dattauli from O/o SMO SDCH Gannaur inspected the Delhi School of Briliants, GT Road Gannaur on 05/08/2024 and found that the Delhi School of Briliants Has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/ State/ U.T. Government.

The above valid for a period of One Year.

HCMS-I
Senior Medical Officer
SDCH Gannaur
Community Health Center
Gannaur (Sonipat)



Sanjay Jain
(Dr Sanjay Jain)
President
For CHIRANJIVI EDUCATIONAL AND
SOCIAL WELFARE SOCIETY

Memo No:-435

Date:-01/05/2025

Subject : Physical / Chemical Examination Report of Water Sample

Sample ID/Classification :	SNP/00394/4/2025 / Private	Sample Details	Date & Time
Sender :	Delhi School Of Brilliants	Collected By	SANDEEP JAIN
Location :	, BAROT, GANNAUR, GT ROAD, SONIPAT	Collection Date	25/04/2025 at 09:02
Sample Description :	Drinking Water	Received at lab	25/04/2025 at 11:27
Latitude / Longitude :	77.038118 / 29.145509	Analysis Start Date	25/04/2025
		Analysis End Date	28/04/2025
		Sample Quantity	2 Ltrs

Test Result (As Per BIS 10500 :2012)

S.No.	Tested Parameter	Result	Requirement (Acceptable Limit)	Permissible Lmt. (In the Absence of Alternate Source)	Protocol Used
1	Turbidity	0.61	1 NTU	5 NTU	APHA 24th Edition -2130 B IS
2	Taste	Agreeable	Agreeable	Agreeable	3025 (Part-8) : 2023 IS 3025
3	Odour	Agreeable	Agreeable 5	Agreeable 15	(Part-5) : 2018 APHA 24th
4	Color	5.0	Hazen Units	Hazen Units	Edition-2120-B APHA 24th Edition
5	Total Dissolved Solids @ 180°C ± 2°C	91	500 mg/lit.	2000 mg/lit.	-2540 C
6	Total Hardness as CaCO ₃	64	200 mg/lit.	600 mg/lit.	APHA 24th Edition -2340 C
7	Calcium as Ca	8.82	75 mg/lit.	200 mg/lit.	APHA 24th Edition-3500-Ca B
8	Magnesium as Mg	10.21	30 mg/lit.	100 mg/lit.	APHA 24th Edition -3500 Mg B
9	Total Alkalinity	42	200 mg/lit.	600 mg/lit.	APHA 24th Edition -2320 B
10	Chloride as Cl	10.99	250 mg/lit.	1000 mg/lit.	APHA 24th Edition -4500 Cl-B
11	Sulphate as So ₄	6	200 mg/lit.	400 mg/lit.	USEPA / APHA 24th -4500 SO ₄ -E
12	Fluoride as F	0.08	1.0 mg/lit.	1.5 mg/lit.	APHA 24th Edition-4500F C/
13	Iron as Fe	0.00	1.0 mg/lit.	1.0 mg/lit.	USEPA
14	Nitrate as No ₃	0.0	45 mg/lit.	45 mg/lit.	APHA 24th Edition -4500 NO ₃ D
15	pH @ 25°C	7.42	6.5 - 8.5	6.5 - 8.5	APHA 24th Edition 4500-H+ B

Remarks :-

- * The Results Given above are related to the sample as received and tested in PHED SONIPAT Lab.
- * The test report can't be regenerated in whole or part there of without written permission of Competent Authority.
- * The test report can't be used for any publicity or any legal purpose.
- * Reliability of water sample lies with sender/collector of water sample.
- * To check the sample report online Scan the QR Code below.
- * The test samples meant for chemical analysis will be disposed off after 7 days from the data of issue of test report unless until specifically requested by the customer for retaining over a longer period.

Water Sample has been found "**CONFORMING**" to Limits set in BIS10500:2012 for the tested parameters.



Sample analyzed by :

DEEPIKA ,CHEMIST
DISTRICT WATER TESTING LABORATORY,SONIPAT
email:-chemist.sonepat@phedharyana.gov.in



Sanjay Jain
(Dr Sanjay Jain)
President
For CHIRANJIVI EDUCATIONAL AND
SOCIAL WELFARE SOCIETY